

Temperature Calibration Report

| Customer: | USGS - Pacific Science Center | | | |
|--------------|-------------------------------|---|-----------------|-----------|
| Job Number: | 64427 |] | Date of Report: | 6/30/2011 |
| Model Number | SBE 03 |] | Serial Number: | 031320 |

Temperature sensors are normally calibrated 'as received', without adjustments, allowing a determination sensor drift. If the calibration identifies a problem, then a second calibration is performed after work is completed. The 'as received' calibration is not performed if the sensor is damaged or non-functional, or by customer request.

An 'as received' calibration certificate is provided, listing coefficients to convert sensor frequency to temperature. Users must choose whether the 'as received' calibration or the previous calibration better represents the sensor condition during deployment. In SEASOFT enter the chosen coefficients using the program SEACON. The coefficient 'offset' allows a small correction for drift between calibrations (consult the SEASOFT manual). Calibration coefficients obtained after a repair apply only to subsequent data.

| 'AS RECEIVED CALIBRATION' | Performed Dot Performed |
|---|---|
| Date: 6/17/2011 | Drift since last cal: -0.00015 Degrees Celsius/year |
| Comments: | |
| | |
| | |
| 'FINAL CALIBRATION' | Performed Not Performed |
| Date: 6/30/2011 | Drift since 31 Mar 01 -0.00016 Degrees Celsius/year |
| Comments: Replaced the main piston O-rings. | |