



SEA-BIRD ELECTRONICS, INC.

13431 NE 20th St. Bellevue, Washington 98005 USA

Phone: (425) 643-9866 Fax: (425) 643-9954 www.seabird.com

Temperature Calibration Report

Customer:	Oregon State University		
Job Number:	77326	Date of Report:	3/5/2014
Model Number	SBE 03-02/F	Serial Number:	031367

Temperature sensors are normally calibrated 'as received', without adjustments, allowing a determination sensor drift. If the calibration identifies a problem, then a second calibration is performed after work is completed. The 'as received' calibration is not performed if the sensor is damaged or non-functional, or by customer request.

An 'as received' calibration certificate is provided, listing coefficients to convert sensor frequency to temperature. Users must choose whether the 'as received' calibration or the previous calibration better represents the sensor condition during deployment. In SEASOFT enter the chosen coefficients. The coefficient 'offset' allows a small correction for drift between calibrations (consult the SEASOFT manual). Calibration coefficients obtained after a repair apply only to subsequent data.

'AS RECEIVED CALIBRATION'

Performed Not Performed

Date: 2/13/2014

Drift since last cal: -0.00022 Degrees Celsius/year

Comments:

'CALIBRATION AFTER MODIFICATION'

Performed Not Performed

Date: 3/5/2014

Drift since 31 Jul 13 -0.00063 Degrees Celsius/year

Comments:

Upgraded to Wet-Pluggable Style Connector.